

ROOMOR OFFICE CABLE 1.0

1681M5B7

GENERAL

PHYSICAL Diameter 560 mm

conditions


 $4.6\,\mathrm{kg}$

Height 216 mm


Project
Туре
Notes
Quantity
Date


Ceiling, Suspended
Black Matt
RAL 9005 ^a
IP20
Interior
Output: 3660 lm
CIE flux code: 65 89 97 100 100
LED
4000 K
CRI ≥ 90
L80 / 60000 h
3 SDCM
OPTICAL
· · · · · · · ·
Microprismatic
UGR < 19
\geq 3000 cd/m ²
ELECTRICAL
DALI-2
220 - 240 V
Total connected power 35 W
Class 1

a Color may deviate slightly due to production



 $VDU\ compatible\ workplace\ luminaire\ according\ to\ DIN\ EN\ 12464-1; luminance\ above\ 65^o \leq 3000\ cd/m^2;$ surface Black Matt wet painted; matt texture; RAL 9005; inclusive adjustable cable suspension max. 2500mm; with COB (Chip on Board) technology for maximum efficiency; light colour 4000 K; binning initial MacAdam ≤ 3 SDCM; CRI ≥ 90; degree of protection IP20; PC1; driver included; light source replaceable by an authorized professional; control gear replaceable by end-user;






May 8, 2024



ROOMOROFFICE CABLE 1.0

1681M5B7

LIGHT DISTRIBUTION



Maintenance Factors

Operating Time [h]			10 000	20 000	30 000	40 000	50 000	
	LSF		0.98	0.95	0.92	1	0.87	
	MF	$LMF \times RSMF \times LLMF \times LSF$			$RSMF^a$	Room Surface Maintenance Factor		
	MF Maintenance Factor			LLMF	Lamp Lumens Maintenance Factor			
LMF ^a Luminaire Maintenance Factor				LSF	Lamp Survival Faktor			

 $^{^{\}rm a}$ According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.