



WEVER & DUCRÉ  
LIGHTING

# ROOMOR OFFICE CABLE 1.0

168185B7

Project

Type

Notes

Quantity

Date

## GENERAL

Ceiling, Suspended

Black Matt

RAL 9005<sup>a</sup>

IP20

Interior

Output: 3700 lm

CIE flux code: 48 79 95 100 100

## LED

4000 K

CRI ≥ 90

L80 / 60000 h

3 SDCM

## OPTICAL

Opal

## ELECTRICAL

DALI-2

220 - 240 V

Total connected power 35 W

Class 1

## PHYSICAL

Diameter 560 mm


Height 216 mm

4.6 kg


<sup>a</sup> Color may deviate slightly due to production conditions.



Round suspended luminaire made from die-cast aluminium; opal PMMA cover; surface Black Matt wet painted; matt texture; RAL 9005; inclusive adjustable cable suspension max. 2500mm; with COB (Chip on Board) technology for maximum efficiency; light colour 4000 K; binning initial MacAdam ≤ 3 SDCM; CRI ≥ 90; degree of protection IP20; PC1; driver included; light source replaceable by an authorized professional; control gear replaceable by end-user;



## LIGHT DISTRIBUTION



[168185B7] The technical data represent rated values for an ambient temperature of 25°C. The data values for the luminous flux are initially subject to a tolerance of +/- 10%, those for the electrical connected load are initially subject to a tolerance of +/- 10%, and those for the colour temperature are initially subject to a tolerance of +/- 150 K. No liability is assumed for typographical or printing errors. The general terms and conditions of Wever & Ducré apply.  
© Wever & Ducré BV · Spinnerijstraat 99/21 · 8500 Kortrijk · Belgium · [www.weverducre.com](http://www.weverducre.com)

May 8, 2024

ROOMOR

OFFICE CABLE 1.0

168185B7

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.95	0.92	0.9	0.87
LSF	1	1	1	1	1

MF	LMF × RSMF × LLMF × LSF		RSMF <sup>a</sup>	Room Surface Maintenance Factor
MF	Maintenance Factor		LLMF	Lamp Lumens Maintenance Factor
LMF <sup>a</sup>	Luminaire Maintenance Factor		LSF	Lamp Survival Faktor

<sup>a</sup> According to “CIE 97, Maintenance of indoor electric lighting systems”, 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.