




PROJECT _____

TYPE _____


NOTES _____

QUANTITY _____

DATE _____



Ceiling suspended luminaire made from aluminium; with 4 spotlights; inclusive adjustable cable suspension max. 2500mm; surface Black Matt; powder coated, matt texture; RAL 9011; with COB (Chip on Board) technology for maximum efficiency; phase-cut dim; light colour 3000 K; ≤ 2 SDCM (initial MacAdam); CRI ≥ 90 ; beam angle 30°; 220 - 240 V; degree of protection IP20; Class 2; UGR ≤ 19 ; driver included; light source replaceable by Wever & Ducré or by a professional with explicit authorization; control gear replaceable by end-user;



LUMINAIRE

Ceiling _____
 Suspended _____
 Black Matt _____
 RAL 9011 ^a _____
 IP20 _____
 Interior _____
 730 lm _____

LED Module

3000 K _____
 CRI ≥ 90 _____
 L80 / 50000h _____
 ≤ 2 SDCM (initial MacAdam) _____
 260 lm _____
 127 lm/W ^b _____

Optical

Medium (standard) _____
 beam angle 30° _____
 UGR ≤ 19 _____
 CIE flux code: 95 99 100 100 _____
 100 _____

Electrical

phase-cut dim _____
 220 - 240 V _____
 system 11.4 W _____
 Class II _____
 Standard _____

Physical


length 1108 mm _____
 width 28 mm _____
 height 50 mm _____
 0.64 kg _____

datasheet.quicksum.material

Aluminium _____

^a Colour may deviate slightly due to production conditions
^b Without electrical and optical losses

LIGHT DISTRIBUTION





Maintenance Factor

Operating Time [h]	10.000	20.000	30.000	40.000	50.000
LLMF	0.98	0.95	0.93	0.9	0.88
LSF	1	1	1	1	1

MF	$LMF \times RSMF \times LLMF \times LSF$	RSMF ^a	Room Surface Maintenance Factor
MF	Maintenance Factor	LLMF	Lamp Lumens Maintenance Factor
LMF ^a	Luminaire Maintenance Factor	LSF	Lamp Survival Factor

^aAccording to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.